Efectis

Efectis Nederland P.O. Box 554 | 2665 ZN Bleiswijk Brandpuntlaan Zuid 16 | 2665 NZ Bleiswijk The Netherlands +31 88 3473 723 nederland@efectis.com



Determination of test fire performance of FT SLAM / FTJN 1010 extinguishing medium according to Annex H of EN 1568-3:2008

Report no.	2017-Efectis-R000964
Sponsor	Fire Terminator International PTE. Ltd Blk. 3015 Ubi Road 1 Unit 04-266 SINGAPORE 408704
Author(s)	P.B. Reijman B.Sc. R.D. Scheepe B.Sc.
Project number	ENL-17-000064
Date of issue	June 2017
Number of pages	12

All rights reserved. No part of this publication may be reproduced and/or published without the previous written consent of Efectis Nederland. Submitting the report for inspection to parties who have a direct interest is permitted.

In case this report was drafted on instructions, the rights and obligations of contracting parties are subject to either the Standard Conditions of Efectis Nederland or the relevant agreement concluded between the contracting parties.





CONTENTS

1.	SUE	BJECT	3
2.	EXA	AMINATION	3
3.	PRI	NCIPAL	3
4.	PLA	CE AND DATES FOR THE EXAMINATION	3
5.	DAT	E AND NUMBER OF THE REPORT	3
6.	INT	RODUCTION	3
6	.1	Foam type and concentrations	3
6	.2	Foam premix	4
6	.3	Test pan	4
6	.4	Fuel	4
6	.5	Nozzle type and positioning	4
6	.6	Foam application	4
7.	TES	ST RESULTS	5
8.	COI	NCLUSIONS	6
APF	PEND	DIX A: PICTURES	7
APF	PPENDIX B: MSDS FT SLAM / FT JN1010 9		





1. SUBJECT

Determination of the test fire performance of liquid concentrate FT SLAM / FT JN 1010.

2. EXAMINATION

Extinguish qualities according to paragraphs of Annex H of EN 1568-3:2008.

3. PRINCIPAL

Fire Terminator International PTE. Ltd Blk. 3015 Ubi Road 1 Unit 04-266 SINGAPORE 408704

4. PLACE AND DATES FOR THE EXAMINATION

The extinguishing tests according Annex H of EN 1568-3:2008 took place on 29th May 2017 at the facilities of the Brandweer Oefencentrum Kleefse Waard Arnhem.

The test fires were carried out indoors at this facilities under controlled climatological circumstances. The tests were performed by staff and with equipments of Efectis Nederland Bleiswijk, The Netherlands.

The tests were witnessed by Mr. H.J. Mondt, Lead Auditor IMS Marine Branch of Bureau Veritas. Also representatives of Fire Terminator International PTE. Ltd were present.

5. DATE AND NUMBER OF THE REPORT

June 2017; 2017-Efectis-R000964.

6. INTRODUCTION

By order of Fire Terminator International PTE. Ltd, Singapore, the Centre of Fire Research of Efectis Nederland carried out extinguishing tests to determine the extinguishing qualities of liquid concentrate FT SLAM / FT JN1010 supplied by the principal. Refer to Annex B of this report for the MSDS of the concentrate.

The fire tests were carried out in accordance with Annex H of EN 1568-3:2008 "*Specification for low expansion foam concentrates for surface application to water immiscible liquids*".

6.1 FOAM TYPE AND CONCENTRATIONS

FT SLAM / FT JN1010 is supplied by Fire Terminator International PTE. Ltd, Singapore. The concentrate was sent from Singapore by air mail in six plastic jerry cans with a volume of 5 litres.

During the tests the foam was applied in premixed form after mixing in a 6% concentration with potable water. The concentration is in accordance with manufacturers recommendations.





6.2 FOAM PREMIX

The foam concentrations mentioned in this report are volume concentrations. The concentration is defined as the ratio of concentrate volume to total volume. Before each test, a stainless steel premix tank was filled with approximately 100 l of the foam mixture. In order to reach the correct concentration, the following procedure was adopted:

- A container was filled with the required volume of concentrate;
- The premix tank was placed on the weighing table and the concentrate poured in the tank;
- The tank was then filled with water. The water flow was stopped when the correct weight was reached;
- The tank was fitted with a pressure connection and connected to a nitrogen cylinder with pressure regulator;
- The tank was pressurized up to a pressure which supplies a nozzle pressure of 6.3 bar with the prescribed foam nozzle this gives a foam flow rate of 11.4 l/min;
- After application of the foam, the nozzle was thoroughly cleaned by circulating water through it for at least 1 minute;
- The premix tank was emptied and rinsed with clean water.

6.3 TEST PAN

The circular fire test pan was made out of mild steel sheet with a thickness of 2.5 mm and had an internal diameter of 2400 mm with a rim height of 200 mm. The internal surface area of the tray is 4.52 m^2 . A burn-back pot was present with an internal diameter of 300 mm and a height of 200 mm.

6.4 FUEL

The test fuel of commercial grade N-Heptane was placed directly on the layer of water in the test pan. In both tests, the mean fuel/water depth was 50 mm. Between the fire tests, the tray was emptied and cleaned, in order to ascertain that there could be no influence from residual matter from a previous test.

6.5 NOZZLE TYPE AND POSITIONING

The foam was discharged using the prescribed standard nozzle. The nozzle was positioned for type H3 forceful application (EN 1568-3 §H.3), i.e. above the horizontal and at a distance from the test pan such that the foam strikes the fuel surface at a point 1 meter from the back edge of the tray. At the end of the foam application the nozzle was manually moved (for approximately 5 seconds) beyond the two adjacent side extensions until full control of the fire was reached.

6.6 FOAM APPLICATION

The foam was to be applied at the rate of nominally 11,4 l/min by applying a pressure of 6.3 bar to the nozzle. The actual flow rate in each test was determined by recording the decrease of the premix tank weight with time, and proved to be in the range 2.50 - 2.55 l/min/m² in all tests. The foam was applied for 3 minutes in each case.





7. TEST RESULTS

Date of performance of extinguishing tests: May 29th 2017

Test pan	: diameter 2.40 m,	A=4.52 m ²
Fuel	: N-Heptane, Commerc	ial grade
Nozzle	: standard	
Concentrate	: FT SLAM / FT JN1010	
Premix	: with potable water	
Density liquid c	oncentrate FT SLAM / JN	1010: 1.089 kg/dm ³

Table 1: Test results

	Test 1:	Test 2:
amount of fuel	144 litres N-Heptane	144 litres N-Heptane
premix (100 litres)	6% premix JN 1010	6% premix JN 1010
expansion (l/kg)	9.7	9.7
25% drainage time	3'40"	3'40"
50% drainage tine	6'15"	6'15"
premix tank pressure	6.5 bar	6.5 bar
nozzle pressure	6.3 bar	6.3 bar
pre-burn time	60 seconds	60 seconds
nozzle	fixed position	fixed position
application	forceful	forceful
mean wind velocity:	<0.1 m/s	<0.1 m/s
mean ambient temperature (air)	22 °C	24 °C
mean premix temperature	19 °C	18 °C
mean fuel temperature	16 °C	16 °C
extinguishing 90%	60 seconds	45 seconds
extinguishing 99%	100 seconds	90 seconds
extinguishing 100%	180 seconds	180 seconds
25 % burn back time	14 minutes	18 minutes
application rate	11.4 l/min.	11.4 l/min.
application density	2.5 l/min/m ²	2.5 l/min/m ²
extinguishing test	passed	passed





8. CONCLUSIONS

The liquid concentrate FT SLAM / FT JN 1010 with 6% concentration proved to be successful in controlling and extinguishing N-Heptane fires in agreement with the specific paragraphs of EN 1568-3:2008.

The Fire extinguishing performance is Class I and the burn-back level is A using potable water.

P.B. Reijman B.Sc. Project Leader Special Testing

R.D. Scheepe B.Sc. Manager Testing





APPENDIX A: PICTURES



Photograph A1: pre-burn phase test fire



Photograph A2: extinguishing phase test fire







Photograph A3: 90% extinguished test fire



Photograph A4: burn-back test





APPENDIX B: MSDS FT SLAM / FT JN1010



	www.fireterminator.com
Address:	Blk. 3015 Ubi Road 1
	Unit 04-266
	Singapore 408 704
Tel:	(65) 6748 4396/ (65) 6454 5494

MATERIAL SAFETY DATA SHEET

FIRE TERMINATOR JN 1010 (Class 'A' 'B' & 'C' Fires)

Page 1 of 4

SECTION 1: IDENTIFI	CATIO	N OF THE MA	TER	IAL AND SUPPLIE	R	
Product Name	Fire-Terminator JN-1010 (Class 'A' & 'B' Fires)			Other Names	None	
Recommended Use		itended or rec uishant for Cl			reparation is as a fire-	
Manufacturer's Name		Fire Terminator International Pte Ltd		Address	Blk3015, Ubi Road 1 #04-266 Singapore 408704	
Telephone No.	(65) 6	6748 4396		Emergency Telephone No.	(65) 6454 5494	
				Date prepared	11 April 2017	
SECTION 2: HAZARD						
Hazard Classification		zardous				
Safety Phrase(s)	Not ava	lot available		k Phrase(s)	Not available	
SECTION 3: COMPOS	ITION	/ INFORMATI				
			ixture cacia Sep, Carom seed Sep and Mineral			
Main Ingredients			Salts.			
Hazardous contents			No PFOS , No PFOA			
SECTION 4: FIRST AI	D MEAS					
		Eye Contact	Flush with large amounts of water. See medical attention.			
		Skin Contact	ntact Wash with soap ar medical attention		nd water. Seek	
		Inhalation		Not expected to be toxic if inhaled.		
		Ingestion	Ingestion Give		Give large amounts of water. Seek medical attention.	
Medical Attention and Treatment	Medical Attention and Special Treatment			See above		









SECTION 10: STABIL	ITY AND REACTIVI	ТҮ			
Chemical Stability	Stable	Conditions to avoid			None
Incompatible Materials	Not applicable		Hazardous Reactions		None
				www	.fireterminator.com
		Address:			Blk. 3015 Ubi Road 1
				Unit 04-266 Singapore 408 704	
	RMINATOR	Tel:	(65	67484	4396/ (65)6454 5494
		Fax:	(00.	, 0, 10	(65) 6836 0120
		i tui.			Page 3 of 4
SECTION 11: TOXICO	DLOGY INFORMATI	ON			
		Eye Contac	t	May ca	ause irritation
		Skin Conta	ct	-	ause mild transient
	de tile ber			irritati	
Health Effects from	the Likely Routes	Inhalation		May ca	ause mild transient
of Exposure				irritation	
		Ingestion		May cause gastrointestinal	
				irritati	
SECTION 12: ECOLO	GICAL INFORMATIO	DN			
Biodegradability		Readily l	biodeg	gradable	1
Eco-Toxicity		Not expe	ected	to be to	xic.
SECTION 13: DISPOS	SAL CONSIDERATIO	NS			
Disposal Methods		Dispose	off in	complia	ance with local, state
		and Commonwealth regulations that may			
		be in for	ce		
Special Precautions Incineration	for Landfill or	Not avail	able		
SECTION 14: TRANS)N			
UN Number	Not applicable		UN Proper Shipping Name		Not applicable
Class and Subsidiary Risk	Not applicable	Packing	Packing Group		Not applicable
Special Precautions for	None	Hazcher	Hazchem Code		Not hazardous
User					
CONTENTS NOT RESTRIC	TED AND NOT REGULAT	ED AS PER IA	ſA.		
Tested Toxin-free by T	TUV SUD PSB (Repo	rt No: 7191	0608	75-CHN	413-EO).
Singapore Green La	bel product				
FRAGILE - Avoid scra	tches, crashes and d	rops while tra	anspo	rting th	e products
SECTION 15: REGUL					
Risk / Safety	Not Classified	Symbol(s) on		Not required





Phrases		Label		
Law on Toxic Material	Not applicable	Fire Fighting Law		Not applicable
Labour Health Safet	y Law on Hazardous M	laterial	Not applic	able

		www.fireterminator.com
	Address:	Blk. 3015 Ubi Road 1
TERMINATOR		Unit 04-266
		Singapore 408 704
	Tel:	(65) 6748 4396/ (65) 6454 5494
	Fax:	(65) 6836 0120
		Page 4 of 4
SECTION 16: OTHER INFORMATION		
Date of preparation	11 Ap	ril 2017

-END OF MSDS-